

REGULATORY UPDATE CALL JUNE 27, 2022 AGENDA

INTEGRATE SOLID WASTE MANAGEMENT FACILITY - BRISTOL, VA

Summary of actions taken since the last call

- SCS Eng went on site for procedure for using GEM to get temperature readings
- Initial temperature readings for 25 wells
- Pump repairs and cleaning station on site
- Additional pumps purchased
- Bristol May 2022 OM&M Report submitted
- Buffer Zone SEM

Proposed Actions

- Addition Pump Maintenance This Week
- Ingenco Blower Upgrades (7/11/2022)
- Install of automated temperature sensors (8/2022)

Odor Issues or Concerns

- Anticipate requesting alternate remedy for the 6 pipe penetrations out of compliance

Operational Issues or Concerns

- Finish moving lines in order to cover LFG lateral, air, and FM piping areas as well as between Wells GW-59, GW-58, GW-66, and GW-57

Upcoming Regulatory Responses

- Plan of Action 7/6/2022

